


5190243IB02

2020261045



Overall Rating: PASS

Report No: 2020261045
Brentano Pattern: TEMAE V220

Sample Accepted on: 19.10.2020
Report Date: 26.10.2020

Total number of pages: 5 (Pg)

TEST	METHOD	RESULT	
* Standard Test Method for Surface Burning Characteristics of Building Materials	ASTM E 84	PASS	
		Class A	
		FSI	SD
		21	170



Seal



Customer Representative
Hasan KUTLU



Laboratory Manager
Hava Sarıaydın

EUROLAB[®] (TÜRCERT TEKNİK KONTROL VE BELGELENDİRME A.Ş.)

It is prohibited to change any and all versions of this document in any manner whatsoever. In case of a conflict between the electronic version (e.g. PDF file) and the original paper version provided by EUROLAB[®], the latter will prevail.

TÜRCERT Teknik Kontrol ve Belgelendirme A.Ş. disclaim liability for any direct, indirect, consequential or incidental damages that may result from the use of the information or data, or from the inability to use the information or data contained in this document.

The contents of this report may only be transmitted to third parties in its entirety and provided with the copyright notice, prohibition to change, electronic versions' validity notice and disclaimer.

Environment

The requirements and standards apply to equipment intended for use in

X	Residential (domestic) environment
X	Commercial and light-industrial environment
X	Industrial environment
X	Medical environment



RESULTS

SUMMARY OF TEST PROCEDURE

Upon ignition of the gas burners, the flame spread distance is observed and recorded every second. Flame spread distance versus time is plotted. Calculations ignore all flame front recessions and Flame Spread Index (FSI) is determined by calculating the total area under the curve for the test sample. If the area under the curve (A) is less than or equal to 97.5 min-ft, then $FSI = 0.515 \cdot A$; if greater, $FSI = 4900 / (195 - A)$. FSI is then rounded to the nearest multiple of 5. Smoke Developed (SD) is determined by dividing the total area under the obscuration curve by that of red oak, and multiplying by 100. SD is then rounded to the nearest multiple of 5 if less than 200. SD values over 200 are rounded to the nearest multiple of 50. Section 5.1.9.1 of ASTM E 84-12c specifies a single combination of lamp and photocell to create the requisite optical system. It is anticipated that alternative, equivalent systems will be permitted in future revisions of the test standard. In May 2012, the Exova tunnel was modified to include a specially-designed optical measurement system that is utilized by many other tunnel systems worldwide. Although an improvement to performance and reliability is realized, as of this date the new system is not specifically recognized by ASTM E 84 so this represents a deviation to the test protocol.

TEST RESULTS

<u>SAMPLE</u>	<u>Flame Spread Index (FSI)</u>	<u>Smoke Developed (SD)</u>
" Tekstil Tabanlı Duvar Kağıdı "	21	170

Observations of Burning Characteristics

- The sample ignited approximately 56 seconds after exposure to the test flame.
- The flame front propagated to a maximum distance of 0.9 metres at approximately 93 seconds.


Classification:

	<u>Flame-Spread Index</u>	<u>Smoke Development</u>
Class 1 or A	0 - 25	450 Maximum
Class 2 or B	26 - 75	450 Maximum
Class 3 or C	76 - 200	450 Maximum


Note: This is an electronic copy of the report. Signatures are on file with the original report.



FLAME SPREAD INDEX



SMOKE DEVELOPED




Flame Spread (Index FSI)

21

Smoke Developed (SD)

170



SAMPLE



**** End of Report ****

